



PS-24

PHOTOELECTRIC SMOKE DETECTOR



P/N 18635

Light Source: GaAIAs Infrared Emitting Diode
Rated Voltage: 17.7 - 33.0 VDC
Working Voltage: 15.0 - 33.0 VDC
Maximum Voltage: 42 VDC
Supervisory Current: 45 μ A Max. at 24 VDC
Surge Current: 160 μ A Max. at 24 VDC
Alarm Current: 150 mA Max. at 24 VDC
Ambient Temperature: 32°F (0°C) to 120°F (49°C)
Sensitivity Test Feature: Automatic Sensitivity window verification test.
Mounting: Refer to Janus Fire Systems® SB Series Smoke Detector Base series, datasheet DS1008.



Standard Features

- Low profile, 1.8" high (with base)
- 2 or 4 wire base compatibility, relay bases available
- Highly stable operation, RF/Transient protection
- Low standby current, 45 μ A at 24 VDC
- Two built-in power/sensitivity supervision/alarm LED's
- Non-directional smoke chamber
- Vandal resistant security locking feature
- Built-in magnetic go/no go detector test feature
- Removable smoke labyrinth for cleaning or replacement
- Automatic Sensitivity window verification function meets outlined requirements in NFPA 72, Chapter 7, Inspection, Testing and Maintenance.

Application

The PS-24 can be used in all areas where Photoelectric Smoke Detectors are required. The wide range smoke chamber makes the PS-24 well suited for fires ranging from smoldering to flaming fires.

SB Series Style bases may be used with the PS-24.

Operation

The PS-24 photoelectric smoke detector utilizes two bi-colored LED's for indication of status. In a normal standby condition the LED's flash *green* every 3 seconds. When the detector senses that its sensitivity has drifted outside the UL listed sensitivity window the LED's will flash *red* every 3 seconds. When the detector senses smoke and goes into alarm the status LED's will latch on *red*.

The detector utilizes an infrared LED light source and silicon photo diode receiving element in the smoke chamber. In a normal standby condition, the receiving element receives no light from the pulsing LED light source. In the event of a fire, smoke enters the detector smoke chamber and light is reflected from the smoke particles to the receiving element. The light received is converted into an electronic signal.

Signals are processed and compared to a reference level, and when two consecutive signals exceeding the reference level are received within a specified period of time, the time delay circuit triggers the SCR switch to activate the alarm signal. The status LED's light continuously during the alarm period.



Engineering Specifications

The contractor shall furnish and install where indicated on the plans, Janus Fire Systems® Model PS-24 photoelectric smoke detectors. The combination detector head and twist-lock base shall be UL listed compatible with a UL listed fire alarm panel.

The base shall be appropriate twist-lock base SB Series.

The smoke detector shall have two flashing status LED's for visual supervision. When the detector is in standby condition the LED's will flash green. When the detector is outside the UL listed sensitivity window the LED's will flash red. When the detector is actuated, the flashing LED's will latch on red. The detector may be reset by actuating the control panel reset switch.

The sensitivity of the detector shall be capable of

being measured. It shall be possible to perform a functional test of the detector without the need of generating smoke. The sensitivity of the detector shall be monitored automatically and continuously to verify that it is operating within the listed sensitivity range.

To facilitate installation, the detector shall be non-polarized. Voltage and RF transient suppression techniques shall be employed to minimize false alarm potential. Auxiliary SPDT relays shall be installed where indicated.

The vandal-resistant, security locking feature shall be used in those areas as indicated on the drawing. The locking feature shall be field removable when not required.

Specifications subject to change without notice.

PS-24 Sensitivity Test Feature

The PS-24 Photoelectric Smoke Detector has a built-in automatic sensitivity test feature.

1. In normal condition, both LED's flash *green*.
2. When the sensitivity drifts outside of its sensitivity limits, both LED's flash *red*.
3. In the alarm state both LED's are *red* continuously.
4. When the sensitivity drifts outside of its sensitivity limits and both LED's flash *red*, the device needs to be cleaned or returned to the factory for cleaning.

Ordering Information		
Model Number	Description	P/N
PS-24	Photoelectric Smoke Detector	18635
SB-46	Smoke Detector Base	18637
SB-81R	Smoke Detector Base w/Relay 81 mA draw	18638

Notes: Approvals/Listings maintained by and manufactured by Potter Electric Signal Company.

The seller makes no warranties, express or implied, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose, except as expressly stated in the seller's sales contract or sales acknowledgment form. Every attempt is made to keep our product information up-to-date and accurate. All specific applications cannot be covered, nor can all requirements be anticipated. All specifications are subject to change without notice.



1102 Rupcich Drive
Millennium Park
Crown Point, IN 46307
TEL: (219) 663-1600 FAX: (219) 663-4562
e-mail: info@janusfiresystems.com
www.janusfiresystems.com